



# PLUMBING INSTALLATION OF INTERIOR NON-METALLIC WATERLINES

CITY OF CLEVELAND HEIGHTS, BUILDING DEPARTMENT

40 Severance Circle  
Cleveland Heights, Ohio 44118  
216-291-4900 / FAX 216-291-4421

## Cleveland Heights Building Code 1301.01(e)2 Rules and Regulations

Prior to replacement of metallic waterlines in an existing structure with non-metallic waterline and prior to issue of a plumbing permit, the owner of such structure shall employ a registered electrical contractor with the City of Cleveland Heights to investigate and evaluate the continuity of all grounding for premises wiring systems, circuits and equipment.

With the removal of the existing metallic waterline system in full or part, the electrical contractor shall determine if the continuity of all grounding for premises wiring systems, circuits and equipment, inclusive of interior and exterior wiring, power, lighting, control and signal circuit wiring together with associated hardware, fittings, serving devices, both permanently and temporarily installed, will be maintained in working order.

All necessary re-grounding of any system, circuits and equipment shall be installed according to the requirements of the current edition of the National Electrical Code by a Registered Electrical Contractor and verified by signature below.

.....

REGARDING PROPERTY ADDRESS: \_\_\_\_\_

Registered Cleveland Heights Electrical Contractor

Print Name \_\_\_\_\_

Address \_\_\_\_\_  
(street address) (city) (state) (zip)

Phone (daytime) \_\_\_\_\_ (home) \_\_\_\_\_

Cleveland Heights Registration # \_\_\_\_\_

Signature of Registered Contractor \_\_\_\_\_